The calibration sheet attached is the original calibration sheet for your REF TEK product and includes contact information and branding for the company that performed the testing.

Reftek Systems Inc. purchased the REF TEK product line in May 2020.

Reftek Systems will honour existing product warranties and extended warranties.

ANY QUESTIONS OR REQUESTS FOR SUPPORT SHOULD BE ADDRESSED AS FOLLOWS:

Sales & Administrative: sales@reftek.com

Support & Engineering: support@reftek.com

Accounting: accounting@reftek.com

Address: 36 Topple Drive, Dartmouth, NS Canada B3B 1L6

Phone: +1-902-444-7650

Fax: +1-902-444-7651

Trimble Navigation Limited
1600 Tenth Street
Suite A
Plano, Texas 75074
Support phone: 1-888-879-2207
Support Email: reftek_support@trimble.com
www.trimble.com/infrastructure

REF TEK 147A-01/3/EXT P/N:97499-00
S/N: 14708

Normalized Magnitude-frequency Characteristics

Freq.(Hz)	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
1.00	1.0026	1.0033	1.0030
10.00	1.0000	1.0000	1.0000
20.00	0.9927	0.9912	0.9918
30.00	0.9825	0.9798	0.9805
40.00	0.9713	0.9686	0.9686
50.00	0.9616	0.9604	0.9589
60.00	0.9547	0.9563	0.9530
70.00	0.9527	0.9574	0.9525
80.00	0.9564	0.9647	0.9588
90.00	0.9662	0.9777	0.9715
100.00	0.9824	0.9968	0.9911
120.00	1.0342	1.0537	1.0499
140.00	1.0968	1.1179	1.1139
160.00	1.1110	1.1192	1.1082

Sensitivities

	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
OutputSensitivity (V/g)	2.502	2.501	2.501
Cross-axis Coupling (g/g)	0.08%	0.20%	0.12%