The calibration sheet attached is the original calibration sheet for your REF TEK product and includes contact information and branding for the company that performed the testing.

Reftek Systems Inc. purchased the REF TEK product line in May 2020.

Reftek Systems will honour existing product warranties and extended warranties.

ANY QUESTIONS OR REQUESTS FOR SUPPORT SHOULD BE ADDRESSED AS FOLLOWS:

Sales & Administrative: sales@reftek.com

Support & Engineering: support@reftek.com

Accounting: accounting@reftek.com

Address: 36 Topple Drive, Dartmouth, NS Canada B3B 1L6

Phone: +1-902-444-7650

Fax: +1-902-444-7651

Trimble Navigation Limited
1600 Tenth Street
Suite A
Plano, Texas 75074
Support phone: 1-888-879-2207
Support Email: reftek_support@trimble.com
www.trimble.com/infrastructure

REF TEK 147A-01/3/EXT P/N:97499-00
S/N: 14709

Normalized Magnitude-frequency Characteristics

Freq.(Hz)	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
1.00	1.0030	1.0031	1.0035
10.00	1.0000	1.0000	1.0000
20.00	0.9918	0.9914	0.9904
30.00	0.9804	0.9797	0.9773
40.00	0.9684	0.9676	0.9640
50.00	0.9585	0.9579	0.9534
60.00	0.9524	0.9519	0.9471
70.00	0.9520	0.9511	0.9468
80.00	0.9588	0.9564	0.9533
90.00	0.9728	0.9677	0.9665
100.00	0.9947	0.9852	0.9865
120.00	1.0624	1.0378	1.0455
140.00	1.1396	1.0959	1.1056
160.00	1.1366	1.0941	1.0876

Sensitivities

	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
OutputSensitivity (V/g)	2.501	2.502	2.500
Cross-axis Coupling (g/g)	0.28%	0.00%	0.00%