



REF TEK

SYSTEMS INC.

The calibration sheet attached is the original calibration sheet for your REF TEK product and includes contact information and branding for the company that performed the testing.

Reftek Systems Inc. purchased the REF TEK product line in May 2020.

Reftek Systems will honour existing product warranties and extended warranties.

ANY QUESTIONS OR REQUESTS FOR SUPPORT SHOULD BE ADDRESSED AS FOLLOWS:

Sales & Administrative: sales@reftek.com

Support & Engineering: support@reftek.com

Accounting: accounting@reftek.com

Address: 36 Topple Drive, Dartmouth, NS Canada B3B 1L6

Phone: +1-902-444-7650

Fax: +1-902-444-7651

Trimble Navigation Limited
 1600 Tenth Street
 Suite A
 Plano, Texas 75074
 Support phone: 1-888-879-2207
 Support Email: reftek_support@trimble.com
www.trimble.com/infrastructure



REF TEK 147A-01/3/EXT P/N:97499-00
S/N: 14715

Normalized Magnitude-frequency Characteristics

Freq.(Hz)	Z-Axis	Y-Axis	X-Axis
	(Vertical)	(North/South)	(East/West)
1.00	1.0033	1.0018	1.0038
10.00	1.0000	1.0000	1.0000
20.00	0.9910	0.9948	0.9900
30.00	0.9790	0.9874	0.9774
40.00	0.9669	0.9792	0.9655
50.00	0.9574	0.9721	0.9567
60.00	0.9516	0.9675	0.9521
70.00	0.9506	0.9672	0.9527
80.00	0.9553	0.9728	0.9596
90.00	0.9655	0.9850	0.9725
100.00	0.9813	1.0048	0.9922
120.00	1.0297	1.0697	1.0532
140.00	1.0845	1.1468	1.1249
160.00	1.0855	1.1389	1.1234

Sensitivities

	Z-Axis	Y-Axis	X-Axis
	(Vertical)	(North/South)	(East/West)
Output Sensitivity (V/g)	2.501	2.498	2.500
Cross-axis Coupling (g/g)	0.20%	0.20%	0.36%