The calibration sheet attached is the original calibration sheet for your REF TEK product and includes contact information and branding for the company that performed the testing.

Reftek Systems Inc. purchased the REF TEK product line in May 2020.

Reftek Systems will honour existing product warranties and extended warranties.

ANY QUESTIONS OR REQUESTS FOR SUPPORT SHOULD BE ADDRESSED AS FOLLOWS:

Sales & Administrative: sales@reftek.com

Support & Engineering: support@reftek.com

Accounting: accounting@reftek.com

Address: 36 Topple Drive, Dartmouth, NS Canada B3B 1L6

Phone: +1-902-444-7650

Fax: +1-902-444-7651

Trimble Navigation Limited
1600 Tenth Street
Suite A
Plano, Texas 75074
Support phone: 1-888-879-2207
Support Email: reftek_support@trimble.com
www.trimble.com/infrastructure

REF TEK 147A-01/3/EXT P/N:97499-00
S/N: 14725

Normalized Magnitude-frequency Characteristics

Freq.(Hz)	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
1.00	1.0032	1.0028	1.0025
10.00	1.0000	1.0000	1.0000
20.00	0.9913	0.9922	0.9930
30.00	0.9798	0.9813	0.9830
40.00	0.9682	0.9696	0.9720
50.00	0.9594	0.9598	0.9623
60.00	0.9546	0.9532	0.9554
70.00	0.9549	0.9516	0.9532
80.00	0.9612	0.9560	0.9569
90.00	0.9730	0.9663	0.9670
100.00	0.9903	0.9827	0.9838
120.00	1.0398	1.0319	1.0372
140.00	1.0893	1.0828	1.0972
160.00	1.0766	1.0737	1.0961

Sensitivities

	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
OutputSensitivity (V/g)	2.500	2.500	2.498
Cross-axis Coupling (g/g)	0.32%	0.32%	0.28%