The calibration sheet attached is the original calibration sheet for your REF TEK product and includes contact information and branding for the company that performed the testing.

Reftek Systems Inc. purchased the REF TEK product line in May 2020.

Reftek Systems will honour existing product warranties and extended warranties.

ANY QUESTIONS OR REQUESTS FOR SUPPORT SHOULD BE ADDRESSED AS FOLLOWS:

Sales & Administrative: sales@reftek.com

Support & Engineering: support@reftek.com

Accounting: accounting@reftek.com

Address: 36 Topple Drive, Dartmouth, NS Canada B3B 1L6

Phone: +1-902-444-7650

Fax: +1-902-444-7651

Trimble Navigation Limited
1600 Tenth Street
Suite A
Plano, Texas 75074
Support phone: 1-888-879-2207
Support Email: reftek_support@trimble.com
www.trimble.com/infrastructure

REF TEK 147A-01/3/EXT P/N:97499-00
S/N: 14739

Normalized Magnitude-frequency Characteristics

Freq.(Hz)	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
1.00	1.0018	1.0018	1.0020
10.00	1.0000	1.0000	1.0000
20.00	0.9948	0.9950	0.9944
30.00	0.9873	0.9878	0.9863
40.00	0.9786	0.9798	0.9773
50.00	0.9705	0.9727	0.9695
60.00	0.9640	0.9678	0.9641
70.00	0.9610	0.9668	0.9630
80.00	0.9624	0.9711	0.9677
90.00	0.9692	0.9812	0.9787
100.00	0.9821	0.9980	0.9970
120.00	1.0291	1.0529	1.0558
140.00	1.0991	1.1201	1.1219
160.00	1.1426	1.1265	1.1087

Sensitivities

	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
OutputSensitivity (V/g)	2.499	2.499	2.502
Cross-axis Coupling (g/g)	0.52%	0.24%	0.08%