



REF TEK

SYSTEMS INC.

The calibration sheet attached is the original calibration sheet for your REF TEK product and includes contact information and branding for the company that performed the testing.

Reftek Systems Inc. purchased the REF TEK product line in May 2020.

Reftek Systems will honour existing product warranties and extended warranties.

ANY QUESTIONS OR REQUESTS FOR SUPPORT SHOULD BE ADDRESSED AS FOLLOWS:

Sales & Administrative: sales@reftek.com

Support & Engineering: support@reftek.com

Accounting: accounting@reftek.com

Address: 36 Tople Drive, Dartmouth, NS Canada B3B 1L6

Phone: +1-902-444-7650

Fax: +1-902-444-7651

Trimble Navigation Limited
1600 Tenth Street
Suite A
Plano, Texas 75074
Support phone: 1-888-879-2207
Support Email: reftek_support@trimble.com
www.trimble.com/infrastructure



REF TEK 147A-01/3/EXT P/N:97499-00
S/N: 14741

Normalized Magnitude-frequency Characteristics

Freq.(Hz)	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
1.00	1.0015	1.0016	1.0016
10.00	1.0000	1.0000	1.0000
20.00	0.9958	0.9956	0.9955
30.00	0.9898	0.9892	0.9889
40.00	0.9831	0.9820	0.9814
50.00	0.9773	0.9754	0.9747
60.00	0.9734	0.9707	0.9696
70.00	0.9730	0.9694	0.9679
80.00	0.9775	0.9726	0.9705
90.00	0.9874	0.9811	0.9781
100.00	1.0036	0.9955	0.9911
120.00	1.0567	1.0431	1.0331
140.00	1.1212	1.0998	1.0779
160.00	1.1235	1.0983	1.0646

Sensitivities

	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
Output Sensitivity (V/g)	2.499	2.500	2.500
Cross-axis Coupling (g/g)	0.88%	0.08%	0.24%