



REF TEK

SYSTEMS INC.

The calibration sheet attached is the original calibration sheet for your REF TEK product and includes contact information and branding for the company that performed the testing.

Reftek Systems Inc. purchased the REF TEK product line in May 2020.

Reftek Systems will honour existing product warranties and extended warranties.

ANY QUESTIONS OR REQUESTS FOR SUPPORT SHOULD BE ADDRESSED AS FOLLOWS:

Sales & Administrative: sales@reftek.com

Support & Engineering: support@reftek.com

Accounting: accounting@reftek.com

Address: 36 Tople Drive, Dartmouth, NS Canada B3B 1L6

Phone: +1-902-444-7650

Fax: +1-902-444-7651

Trimble Navigation Limited
 1600 Tenth Street
 Suite A
 Plano, Texas 75074
 Support phone: 1-888-879-2207
 Support Email: reftek_support@trimble.com
www.trimble.com/infrastructure



REF TEK 147A-01/3/EXT P/N:97499-00
S/N: 14744

Normalized Magnitude-frequency Characteristics

Freq.(Hz)	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
1.00	1.0018	1.0017	1.0020
10.00	1.0000	1.0000	1.0000
20.00	0.9949	0.9953	0.9944
30.00	0.9876	0.9885	0.9863
40.00	0.9797	0.9809	0.9772
50.00	0.9732	0.9742	0.9690
60.00	0.9693	0.9696	0.9630
70.00	0.9699	0.9688	0.9609
80.00	0.9766	0.9730	0.9641
90.00	0.9896	0.9827	0.9731
100.00	1.0097	0.9988	0.9886
120.00	1.0707	1.0505	1.0389
140.00	1.1297	1.1100	1.0944
160.00	1.0966	1.1051	1.0818

Sensitivities

	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
Output Sensitivity (V/g)	2.501	2.499	2.500
Cross-axis Coupling (g/g)	0.08%	0.00%	0.24%