



REF TEK

SYSTEMS INC.

The calibration sheet attached is the original calibration sheet for your REF TEK product and includes contact information and branding for the company that performed the testing.

Reftek Systems Inc. purchased the REF TEK product line in May 2020.

Reftek Systems will honour existing product warranties and extended warranties.

ANY QUESTIONS OR REQUESTS FOR SUPPORT SHOULD BE ADDRESSED AS FOLLOWS:

Sales & Administrative: sales@reftek.com

Support & Engineering: support@reftek.com

Accounting: accounting@reftek.com

Address: 36 Topple Drive, Dartmouth, NS Canada B3B 1L6

Phone: +1-902-444-7650

Fax: +1-902-444-7651

Trimble Navigation Limited
 1600 Tenth Street
 Suite A
 Plano, Texas 75074
 Support phone: 1-888-879-2207
 Support Email: reftek_support@trimble.com
www.trimble.com/infrastructure



REF TEK 147A-01/3/EXT P/N:97499-00
S/N: 14751

Normalized Magnitude-frequency Characteristics

Freq.(Hz)	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
1.00	1.0021	1.0020	1.0019
10.00	1.0000	1.0000	1.0000
20.00	0.9941	0.9945	0.9946
30.00	0.9857	0.9865	0.9868
40.00	0.9764	0.9778	0.9781
50.00	0.9682	0.9703	0.9703
60.00	0.9625	0.9654	0.9649
70.00	0.9614	0.9649	0.9634
80.00	0.9661	0.9705	0.9673
90.00	0.9775	0.9826	0.9772
100.00	0.9963	1.0022	0.9938
120.00	1.0577	1.0648	1.0478
140.00	1.1296	1.1352	1.1104
160.00	1.1241	1.1223	1.1059

Sensitivities

	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
Output Sensitivity (V/g)	2.499	2.500	2.499
Cross-axis Coupling (g/g)	0.12%	0.20%	0.28%