



REF TEK

SYSTEMS INC.

The calibration sheet attached is the original calibration sheet for your REF TEK product and includes contact information and branding for the company that performed the testing.

Reftek Systems Inc. purchased the REF TEK product line in May 2020.

Reftek Systems will honour existing product warranties and extended warranties.

ANY QUESTIONS OR REQUESTS FOR SUPPORT SHOULD BE ADDRESSED AS FOLLOWS:

Sales & Administrative: sales@reftek.com

Support & Engineering: support@reftek.com

Accounting: accounting@reftek.com

Address: 36 Topple Drive, Dartmouth, NS Canada B3B 1L6

Phone: +1-902-444-7650

Fax: +1-902-444-7651

Trimble Navigation Limited
 1600 Tenth Street
 Suite A
 Plano, Texas 75074
 Support phone: 1-888-879-2207
 Support Email: reftek_support@trimble.com
www.trimble.com/infrastructure



REF TEK 147A-01/3/EXT P/N:97499-00
S/N: 14756

Normalized Magnitude-frequency Characteristics

Freq.(Hz)	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
1.00	1.0017	1.0018	1.0015
10.00	1.0000	1.0000	1.0000
20.00	0.9952	0.9949	0.9958
30.00	0.9882	0.9876	0.9899
40.00	0.9806	0.9794	0.9833
50.00	0.9741	0.9721	0.9777
60.00	0.9701	0.9670	0.9743
70.00	0.9703	0.9659	0.9745
80.00	0.9765	0.9703	0.9800
90.00	0.9891	0.9808	0.9910
100.00	1.0093	0.9985	1.0086
120.00	1.0750	1.0580	1.0643
140.00	1.1532	1.1330	1.1275
160.00	1.1458	1.1377	1.1180

Sensitivities

	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
Output Sensitivity (V/g)	2.500	2.497	2.500
Cross-axis Coupling (g/g)	0.32%	0.32%	0.76%