



REF TEK

SYSTEMS INC.

The calibration sheet attached is the original calibration sheet for your REF TEK product and includes contact information and branding for the company that performed the testing.

Reftek Systems Inc. purchased the REF TEK product line in May 2020.

Reftek Systems will honour existing product warranties and extended warranties.

ANY QUESTIONS OR REQUESTS FOR SUPPORT SHOULD BE ADDRESSED AS FOLLOWS:

Sales & Administrative: sales@reftek.com

Support & Engineering: support@reftek.com

Accounting: accounting@reftek.com

Address: 36 Tople Drive, Dartmouth, NS Canada B3B 1L6

Phone: +1-902-444-7650

Fax: +1-902-444-7651

Trimble Navigation Limited
 1600 Tenth Street
 Suite A
 Plano, Texas 75074
 Support phone: 1-888-879-2207
 Support Email: reftek_support@trimble.com
www.trimble.com/infrastructure



REF TEK 147A-01/3/EXT P/N:97499-00
S/N: 14757

Normalized Magnitude-frequency Characteristics

Freq.(Hz)	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
1.00	1.0018	1.0016	1.0019
10.00	1.0000	1.0000	1.0000
20.00	0.9948	0.9955	0.9945
30.00	0.9873	0.9890	0.9865
40.00	0.9789	0.9816	0.9774
50.00	0.9715	0.9748	0.9689
60.00	0.9662	0.9698	0.9625
70.00	0.9649	0.9681	0.9598
80.00	0.9689	0.9710	0.9620
90.00	0.9788	0.9790	0.9700
100.00	0.9956	0.9929	0.9844
120.00	1.0505	1.0397	1.0335
140.00	1.1136	1.0966	1.0921
160.00	1.1048	1.0978	1.0875

Sensitivities

	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
Output Sensitivity (V/g)	2.502	2.502	2.500
Cross-axis Coupling (g/g)	0.04%	0.16%	0.32%