



REF TEK

SYSTEMS INC.

The calibration sheet attached is the original calibration sheet for your REF TEK product and includes contact information and branding for the company that performed the testing.

Reftek Systems Inc. purchased the REF TEK product line in May 2020.

Reftek Systems will honour existing product warranties and extended warranties.

ANY QUESTIONS OR REQUESTS FOR SUPPORT SHOULD BE ADDRESSED AS FOLLOWS:

Sales & Administrative: sales@reftek.com

Support & Engineering: support@reftek.com

Accounting: accounting@reftek.com

Address: 36 Topple Drive, Dartmouth, NS Canada B3B 1L6

Phone: +1-902-444-7650

Fax: +1-902-444-7651

Trimble Navigation Limited
 1600 Tenth Street
 Suite A
 Plano, Texas 75074
 Support phone: 1-888-879-2207
 Support Email: reftek_support@trimble.com
www.trimble.com/infrastructure



REF TEK 147A-01/3/EXT P/N:97499-00
S/N: 14759

Normalized Magnitude-frequency Characteristics

Freq.(Hz)	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
1.00	1.0017	1.0019	1.0017
10.00	1.0000	1.0000	1.0000
20.00	0.9952	0.9947	0.9953
30.00	0.9884	0.9872	0.9887
40.00	0.9808	0.9787	0.9814
50.00	0.9741	0.9712	0.9752
60.00	0.9696	0.9660	0.9715
70.00	0.9689	0.9649	0.9717
80.00	0.9734	0.9692	0.9774
90.00	0.9834	0.9795	0.9890
100.00	0.9999	0.9969	1.0071
120.00	1.0527	1.0540	1.0630
140.00	1.1150	1.1248	1.1221
160.00	1.1161	1.1320	1.1058

Sensitivities

	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
Output Sensitivity (V/g)	2.504	2.502	2.499
Cross-axis Coupling (g/g)	0.24%	0.08%	0.16%