



REF TEK

SYSTEMS INC.

The calibration sheet attached is the original calibration sheet for your REF TEK product and includes contact information and branding for the company that performed the testing.

Reftek Systems Inc. purchased the REF TEK product line in May 2020.

Reftek Systems will honour existing product warranties and extended warranties.

ANY QUESTIONS OR REQUESTS FOR SUPPORT SHOULD BE ADDRESSED AS FOLLOWS:

Sales & Administrative: sales@reftek.com

Support & Engineering: support@reftek.com

Accounting: accounting@reftek.com

Address: 36 Tople Drive, Dartmouth, NS Canada B3B 1L6

Phone: +1-902-444-7650

Fax: +1-902-444-7651

Trimble Navigation Limited
 1600 Tenth Street
 Suite A
 Plano, Texas 75074
 Support phone: 1-888-879-2207
 Support Email: reftek_support@trimble.com
www.trimble.com/infrastructure



REF TEK 147A-01/3/EXT P/N:97499-00
S/N: 14762

Normalized Magnitude-frequency Characteristics

Freq.(Hz)	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
1.00	1.0014	1.0019	1.0013
10.00	1.0000	1.0000	1.0000
20.00	0.9961	0.9946	0.9963
30.00	0.9903	0.9868	0.9910
40.00	0.9838	0.9781	0.9851
50.00	0.9780	0.9704	0.9800
60.00	0.9738	0.9651	0.9767
70.00	0.9728	0.9640	0.9766
80.00	0.9761	0.9686	0.9809
90.00	0.9844	0.9796	0.9902
100.00	0.9985	0.9982	1.0051
120.00	1.0457	1.0590	1.0531
140.00	1.1054	1.1279	1.1101
160.00	1.1123	1.1075	1.1105

Sensitivities

	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
Output Sensitivity (V/g)	2.504	2.503	2.499
Cross-axis Coupling (g/g)	0.12%	0.24%	0.52%