The calibration sheet attached is the original calibration sheet for your REF TEK product and includes contact information and branding for the company that performed the testing.

Reftek Systems Inc. purchased the REF TEK product line in May 2020.

Reftek Systems will honour existing product warranties and extended warranties.

ANY QUESTIONS OR REQUESTS FOR SUPPORT SHOULD BE ADDRESSED AS FOLLOWS:

Sales & Administrative: sales@reftek.com

Support & Engineering: support@reftek.com

Accounting: accounting@reftek.com

Address: 36 Topple Drive, Dartmouth, NS Canada B3B 1L6

Phone: +1-902-444-7650

Fax: +1-902-444-7651

Trimble Navigation Limited
1600 Tenth Street
Suite A
Plano, Texas 75074
Support phone: 1-888-879-2207
Support Email: reftek_support@trimble.com
www.trimble.com/infrastructure

REF TEK 147A-01/3/EXT P/N:97499-00
S/N: 14764

Normalized Magnitude-frequency Characteristics

Freq.(Hz)	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
1.00	1.0017	1.0022	1.0017
10.00	1.0000	1.0000	1.0000
20.00	0.9953	0.9938	0.9952
30.00	0.9885	0.9848	0.9884
40.00	0.9811	0.9746	0.9807
50.00	0.9749	0.9652	0.9739
60.00	0.9712	0.9581	0.9692
70.00	0.9716	0.9552	0.9682
80.00	0.9778	0.9578	0.9724
90.00	0.9902	0.9667	0.9823
100.00	1.0098	0.9827	0.9989
120.00	1.0713	1.0366	1.0535
140.00	1.1373	1.0974	1.1209
160.00	1.1162	1.0793	1.1262

Sensitivities

	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
OutputSensitivity (V/g)	2.499	2.500	2.503
Cross-axis Coupling (g/g)	0.04%	0.32%	0.12%