The calibration sheet attached is the original calibration sheet for your REF TEK product and includes contact information and branding for the company that performed the testing.

Reftek Systems Inc. purchased the REF TEK product line in May 2020.

Reftek Systems will honour existing product warranties and extended warranties.

ANY QUESTIONS OR REQUESTS FOR SUPPORT SHOULD BE ADDRESSED AS FOLLOWS:

Sales & Administrative: sales@reftek.com

Support & Engineering: support@reftek.com

Accounting: accounting@reftek.com

Address: 36 Topple Drive, Dartmouth, NS Canada B3B 1L6

Phone: +1-902-444-7650

Fax: +1-902-444-7651

Trimble Navigation Limited
1600 Tenth Street
Suite A
Plano, Texas 75074
Support phone: 1-888-879-2207
Support Email: reftek_support@trimble.com
www.trimble.com/infrastructure

REF TEK 147A-01/3/EXT P/N:97499-00
S/N: 14765

Normalized Magnitude-frequency Characteristics

Freq.(Hz)	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
1.00	1.0016	1.0017	1.0020
10.00	1.0000	1.0000	1.0000
20.00	0.9955	0.9952	0.9945
30.00	0.9889	0.9882	0.9864
40.00	0.9814	0.9803	0.9771
50.00	0.9744	0.9732	0.9685
60.00	0.9690	0.9680	0.9617
70.00	0.9669	0.9663	0.9586
80.00	0.9692	0.9695	0.9601
90.00	0.9767	0.9783	0.9673
100.00	0.9903	0.9932	0.9807
120.00	1.0388	1.0427	1.0272
140.00	1.1076	1.0999	1.0832
160.00	1.1369	1.0911	1.0800

Sensitivities

	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
OutputSensitivity (V/g)	2.500	2.499	2.499
Cross-axis Coupling (g/g)	0.16%	0.04%	0.12%