



REF TEK

SYSTEMS INC.

The calibration sheet attached is the original calibration sheet for your REF TEK product and includes contact information and branding for the company that performed the testing.

Reftek Systems Inc. purchased the REF TEK product line in May 2020.

Reftek Systems will honour existing product warranties and extended warranties.

ANY QUESTIONS OR REQUESTS FOR SUPPORT SHOULD BE ADDRESSED AS FOLLOWS:

Sales & Administrative: sales@reftek.com

Support & Engineering: support@reftek.com

Accounting: accounting@reftek.com

Address: 36 Topple Drive, Dartmouth, NS Canada B3B 1L6

Phone: +1-902-444-7650

Fax: +1-902-444-7651

Trimble Navigation Limited
1600 Tenth Street
Suite A
Plano, Texas 75074
Support phone: 1-888-879-2207
Support Email: reftek_support@trimble.com
www.trimble.com/infrastructure



REF TEK 147A-01/3 P/N:97499-00
S/N: 14775

Normalized Magnitude-frequency Characteristics

Freq.(Hz)	Z Axis (Vertical)	Y Axis (North/South)	X Axis (East/West)
1.00	1.0025	1.0020	1.0017
10.00	1.0000	1.0000	1.0000
20.00	0.9929	0.9944	0.9953
30.00	0.9826	0.9864	0.9885
40.00	0.9711	0.9775	0.9808
50.00	0.9607	0.9695	0.9737
60.00	0.9529	0.9640	0.9686
70.00	0.9500	0.9628	0.9668
80.00	0.9536	0.9674	0.9698
90.00	0.9644	0.9784	0.9780
100.00	0.9835	0.9968	0.9924
120.00	1.0473	1.0572	1.0404
140.00	1.1152	1.1261	1.0977
160.00	1.0763	1.1108	1.0947

Sensitivities

	Z Axis (Vertical)	Y Axis (North/South)	X Axis (East/West)
OutputSensitivity (V/g)	2.499	2.500	2.497
Cross-axis Coupling (g/g)	0.28%	0.24%	0.36%