The calibration sheet attached is the original calibration sheet for your REF TEK product and includes contact information and branding for the company that performed the testing.

Reftek Systems Inc. purchased the REF TEK product line in May 2020.

Reftek Systems will honour existing product warranties and extended warranties.

ANY QUESTIONS OR REQUESTS FOR SUPPORT SHOULD BE ADDRESSED AS FOLLOWS:

Sales & Administrative: sales@reftek.com

Support & Engineering: support@reftek.com

Accounting: accounting@reftek.com

Address: 36 Topple Drive, Dartmouth, NS Canada B3B 1L6

Phone: +1-902-444-7650

Fax: +1-902-444-7651

Trimble Navigation Limited
1600 Tenth Street
Suite A
Plano, Texas 75074
Support phone: 1-888-879-2207
Support Email: reftek_support@trimble.com
www.trimble.com/infrastructure

REF TEK 147A-01/3/EXT P/N:97499-00
S/N: 14788

Normalized Magnitude-frequency Characteristics

Freq.(Hz)	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
1.00	1.0018	1.0019	1.0018
10.00	1.0000	1.0000	1.0000
20.00	0.9948	0.9947	0.9948
30.00	0.9872	0.9871	0.9874
40.00	0.9788	0.9784	0.9789
50.00	0.9711	0.9705	0.9712
60.00	0.9657	0.9646	0.9655
70.00	0.9642	0.9624	0.9636
80.00	0.9680	0.9653	0.9667
90.00	0.9777	0.9740	0.9756
100.00	0.9943	0.9895	0.9911
120.00	1.0488	1.0424	1.0431
140.00	1.1106	1.1085	1.1070
160.00	1.0958	1.1100	1.1091

Sensitivities

	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
OutputSensitivity (V/g)	2.499	2.502	2.499
Cross-axis Coupling (g/g)	0.80%	0.04%	0.40%