The calibration sheet attached is the original calibration sheet for your REF TEK product and includes contact information and branding for the company that performed the testing.

Reftek Systems Inc. purchased the REF TEK product line in May 2020.

Reftek Systems will honour existing product warranties and extended warranties.

ANY QUESTIONS OR REQUESTS FOR SUPPORT SHOULD BE ADDRESSED AS FOLLOWS:

Sales & Administrative: sales@reftek.com

Support & Engineering: support@reftek.com

Accounting: accounting@reftek.com

Address: 36 Topple Drive, Dartmouth, NS Canada B3B 1L6

Phone: +1-902-444-7650

Fax: +1-902-444-7651

Trimble Navigation Limited
1600 Tenth Street
Suite A
Plano, Texas 75074
Support phone: 1-888-879-2207
Support Email: reftek_support@trimble.com
www.trimble.com/infrastructure

REF TEK 147A-01/3/EXT P/N:97499-00
S/N: 14795

Normalized Magnitude-frequency Characteristics

Freq.(Hz)	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
1.00	1.0017	1.0017	1.0016
10.00	1.0000	1.0000	1.0000
20.00	0.9951	0.9952	0.9956
30.00	0.9881	0.9883	0.9892
40.00	0.9801	0.9805	0.9819
50.00	0.9730	0.9735	0.9755
60.00	0.9679	0.9686	0.9709
70.00	0.9665	0.9673	0.9697
80.00	0.9702	0.9711	0.9732
90.00	0.9798	0.9807	0.9820
100.00	0.9962	0.9970	0.9968
120.00	1.0515	1.0520	1.0452
140.00	1.1218	1.1225	1.1016
160.00	1.1289	1.1324	1.0968

Sensitivities

	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
OutputSensitivity (V/g)	2.505	2.499	2.499
Cross-axis Coupling (g/g)	0.44%	0.44%	0.28%