



REF TEK

SYSTEMS INC.

The calibration sheet attached is the original calibration sheet for your REF TEK product and includes contact information and branding for the company that performed the testing.

Reftek Systems Inc. purchased the REF TEK product line in May 2020.

Reftek Systems will honour existing product warranties and extended warranties.

ANY QUESTIONS OR REQUESTS FOR SUPPORT SHOULD BE ADDRESSED AS FOLLOWS:

Sales & Administrative: sales@reftek.com

Support & Engineering: support@reftek.com

Accounting: accounting@reftek.com

Address: 36 Topple Drive, Dartmouth, NS Canada B3B 1L6

Phone: +1-902-444-7650

Fax: +1-902-444-7651

Trimble Navigation Limited
 1600 Tenth Street
 Suite A
 Plano, Texas 75074
 Support phone: 1-888-879-2207
 Support Email: reftek_support@trimble.com
www.trimble.com/infrastructure



REF TEK 147A-01/3/EXT P/N:97499-00
S/N: 14805

Normalized Magnitude-frequency Characteristics

Freq.(Hz)	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
1.00	1.0019	1.0018	1.0019
10.00	1.0000	1.0000	1.0000
20.00	0.9946	0.9950	0.9947
30.00	0.9869	0.9879	0.9872
40.00	0.9783	0.9800	0.9789
50.00	0.9707	0.9734	0.9716
60.00	0.9655	0.9693	0.9668
70.00	0.9644	0.9694	0.9662
80.00	0.9688	0.9754	0.9712
90.00	0.9793	0.9877	0.9825
100.00	0.9966	1.0073	1.0008
120.00	1.0525	1.0693	1.0596
140.00	1.1154	1.1398	1.1273
160.00	1.1063	1.1306	1.1209

Sensitivities

	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
Output Sensitivity (V/g)	2.504	2.502	2.498
Cross-axis Coupling (g/g)	0.72%	0.84%	0.64%