The calibration sheet attached is the original calibration sheet for your REF TEK product and includes contact information and branding for the company that performed the testing.

Reftek Systems Inc. purchased the REF TEK product line in May 2020.

Reftek Systems will honour existing product warranties and extended warranties.

ANY QUESTIONS OR REQUESTS FOR SUPPORT SHOULD BE ADDRESSED AS FOLLOWS:

Sales & Administrative: sales@reftek.com

Support & Engineering: support@reftek.com

Accounting: accounting@reftek.com

Address: 36 Topple Drive, Dartmouth, NS Canada B3B 1L6

Phone: +1-902-444-7650

Fax: +1-902-444-7651

Trimble Navigation Limited
1600 Tenth Street
Suite A
Plano, Texas 75074
Support phone: 1-888-879-2207
Support Email: reftek_support@trimble.com
www.trimble.com/infrastructure

REF TEK 147A-01/3/EXT P/N:97499-00
S/N: 14807

Normalized Magnitude-frequency Characteristics

Freq.(Hz)	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
1.00	1.0018	1.0021	1.0015
10.00	1.0000	1.0000	1.0000
20.00	0.9950	0.9942	0.9958
30.00	0.9879	0.9859	0.9897
40.00	0.9799	0.9766	0.9826
50.00	0.9728	0.9684	0.9762
60.00	0.9679	0.9628	0.9713
70.00	0.9670	0.9616	0.9696
80.00	0.9715	0.9666	0.9721
90.00	0.9822	0.9784	0.9795
100.00	1.0001	0.9981	0.9926
120.00	1.0598	1.0628	1.0381
140.00	1.1327	1.1349	1.0985
160.00	1.1289	1.1083	1.1142

Sensitivities

	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
OutputSensitivity (V/g)	2.496	2.501	2.500
Cross-axis Coupling (g/g)	0.40%	0.56%	0.56%