



REF TEK

SYSTEMS INC.

The calibration sheet attached is the original calibration sheet for your REF TEK product and includes contact information and branding for the company that performed the testing.

Reftek Systems Inc. purchased the REF TEK product line in May 2020.

Reftek Systems will honour existing product warranties and extended warranties.

ANY QUESTIONS OR REQUESTS FOR SUPPORT SHOULD BE ADDRESSED AS FOLLOWS:

Sales & Administrative: sales@reftek.com

Support & Engineering: support@reftek.com

Accounting: accounting@reftek.com

Address: 36 Topple Drive, Dartmouth, NS Canada B3B 1L6

Phone: +1-902-444-7650

Fax: +1-902-444-7651

Trimble Navigation Limited
1600 Tenth Street
Suite A
Plano, Texas 75074
Support phone: 1-888-879-2207
Support Email: reftek_support@trimble.com
www.trimble.com/infrastructure



REF TEK 147A-01/3/EXT P/N:97499-00
S/N: 14810

Normalized Magnitude-frequency Characteristics

Freq.(Hz)	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
1.00	1.0018	1.0016	1.0017
10.00	1.0000	1.0000	1.0000
20.00	0.9948	0.9955	0.9951
30.00	0.9873	0.9891	0.9880
40.00	0.9789	0.9820	0.9800
50.00	0.9715	0.9759	0.9729
60.00	0.9663	0.9719	0.9678
70.00	0.9651	0.9716	0.9665
80.00	0.9692	0.9763	0.9701
90.00	0.9793	0.9865	0.9791
100.00	0.9961	1.0029	0.9942
120.00	1.0508	1.0549	1.0428
140.00	1.1145	1.1145	1.0973
160.00	1.1090	1.1127	1.0898

Sensitivities

	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
OutputSensitivity (V/g)	2.503	2.500	2.502
Cross-axis Coupling (g/g)	0.92%	0.68%	0.08%