



REF TEK

SYSTEMS INC.

The calibration sheet attached is the original calibration sheet for your REF TEK product and includes contact information and branding for the company that performed the testing.

Reftek Systems Inc. purchased the REF TEK product line in May 2020.

Reftek Systems will honour existing product warranties and extended warranties.

ANY QUESTIONS OR REQUESTS FOR SUPPORT SHOULD BE ADDRESSED AS FOLLOWS:

Sales & Administrative: sales@reftek.com

Support & Engineering: support@reftek.com

Accounting: accounting@reftek.com

Address: 36 Tople Drive, Dartmouth, NS Canada B3B 1L6

Phone: +1-902-444-7650

Fax: +1-902-444-7651

Trimble Navigation Limited
 1600 Tenth Street
 Suite A
 Plano, Texas 75074
 Support phone: 1-888-879-2207
 Support Email: reftek_support@trimble.com
www.trimble.com/infrastructure



REF TEK 147A-01/3/EXT P/N:97499-00
S/N: 14816

Normalized Magnitude-frequency Characteristics

Freq.(Hz)	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
1.00	1.0020	1.0019	1.0019
10.00	1.0000	1.0000	1.0000
20.00	0.9944	0.9947	0.9946
30.00	0.9864	0.9870	0.9869
40.00	0.9773	0.9784	0.9782
50.00	0.9691	0.9707	0.9706
60.00	0.9631	0.9651	0.9654
70.00	0.9610	0.9635	0.9642
80.00	0.9641	0.9670	0.9685
90.00	0.9730	0.9762	0.9789
100.00	0.9885	0.9918	0.9959
120.00	1.0395	1.0421	1.0504
140.00	1.0995	1.0975	1.1107
160.00	1.0984	1.0864	1.0990

Sensitivities

	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
Output Sensitivity (V/g)	2.501	2.499	2.505
Cross-axis Coupling (g/g)	0.08%	0.24%	0.20%