



REF TEK

SYSTEMS INC.

The calibration sheet attached is the original calibration sheet for your REF TEK product and includes contact information and branding for the company that performed the testing.

Reftek Systems Inc. purchased the REF TEK product line in May 2020.

Reftek Systems will honour existing product warranties and extended warranties.

ANY QUESTIONS OR REQUESTS FOR SUPPORT SHOULD BE ADDRESSED AS FOLLOWS:

Sales & Administrative: sales@reftek.com

Support & Engineering: support@reftek.com

Accounting: accounting@reftek.com

Address: 36 Topple Drive, Dartmouth, NS Canada B3B 1L6

Phone: +1-902-444-7650

Fax: +1-902-444-7651

Trimble Navigation Limited
 1600 Tenth Street
 Suite A
 Plano, Texas 75074
 Support phone: 1-888-879-2207
 Support Email: reftek_support@trimble.com
www.trimble.com/infrastructure



REF TEK 147A-01/3/EXT P/N:97499-00
S/N: 14817

Normalized Magnitude-frequency Characteristics

Freq.(Hz)	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
1.00	1.0017	1.0018	1.0021
10.00	1.0000	1.0000	1.0000
20.00	0.9953	0.9950	0.9941
30.00	0.9885	0.9877	0.9855
40.00	0.9809	0.9793	0.9758
50.00	0.9742	0.9715	0.9668
60.00	0.9696	0.9656	0.9599
70.00	0.9687	0.9630	0.9568
80.00	0.9728	0.9649	0.9589
90.00	0.9823	0.9721	0.9668
100.00	0.9981	0.9852	0.9813
120.00	1.0495	1.0302	1.0309
140.00	1.1121	1.0873	1.0929
160.00	1.1204	1.0950	1.0980

Sensitivities

	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
Output Sensitivity (V/g)	2.501	2.499	2.500
Cross-axis Coupling (g/g)	0.96%	0.56%	0.00%