The calibration sheet attached is the original calibration sheet for your REF TEK product and includes contact information and branding for the company that performed the testing.

Reftek Systems Inc. purchased the REF TEK product line in May 2020.

Reftek Systems will honour existing product warranties and extended warranties.

ANY QUESTIONS OR REQUESTS FOR SUPPORT SHOULD BE ADDRESSED AS FOLLOWS:

Sales & Administrative: sales@reftek.com

Support & Engineering: support@reftek.com

Accounting: accounting@reftek.com

Address: 36 Topple Drive, Dartmouth, NS Canada B3B 1L6

Phone: +1-902-444-7650

Fax: +1-902-444-7651

Trimble Navigation Limited
1600 Tenth Street
Suite A
Plano, Texas 75074
Support phone: 1-888-879-2207
Support Email: reftek_support@trimble.com
www.trimble.com/infrastructure

REF TEK 147A-01/3/EXT P/N:97499-00
S/N: 14818

Normalized Magnitude-frequency Characteristics

Freq.(Hz)	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
1.00	1.0023	1.0021	1.0020
10.00	1.0000	1.0000	1.0000
20.00	0.9936	0.9940	0.9944
30.00	0.9843	0.9855	0.9863
40.00	0.9740	0.9758	0.9774
50.00	0.9647	0.9671	0.9697
60.00	0.9579	0.9607	0.9646
70.00	0.9557	0.9585	0.9639
80.00	0.9594	0.9619	0.9693
90.00	0.9698	0.9715	0.9812
100.00	0.9876	0.9881	1.0005
120.00	1.0466	1.0440	1.0623
140.00	1.1138	1.1141	1.1296
160.00	1.0997	1.1237	1.1086

Sensitivities

	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
OutputSensitivity (V/g)	2.502	2.501	2.500
Cross-axis Coupling (g/g)	0.48%	0.16%	0.76%