The calibration sheet attached is the original calibration sheet for your REF TEK product and includes contact information and branding for the company that performed the testing.

Reftek Systems Inc. purchased the REF TEK product line in May 2020.

Reftek Systems will honour existing product warranties and extended warranties.

ANY QUESTIONS OR REQUESTS FOR SUPPORT SHOULD BE ADDRESSED AS FOLLOWS:

Sales & Administrative: sales@reftek.com

Support & Engineering: support@reftek.com

Accounting: accounting@reftek.com

Address: 36 Topple Drive, Dartmouth, NS Canada B3B 1L6

Phone: +1-902-444-7650

Fax: +1-902-444-7651

Trimble Navigation Limited
1600 Tenth Street
Suite A
Plano, Texas 75074
Support phone: 1-888-879-2207
Support Email: reftek_support@trimble.com
www.trimble.com/infrastructure

REF TEK 147A-01/3/EXT
S/N: 14846

Normalized Magnitude-frequency Characteristics

Freq.(Hz)	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
1.00	1.0020	1.0020	1.0023
10.00	1.0000	1.0000	1.0000
20.00	0.9945	0.9943	0.9935
30.00	0.9867	0.9861	0.9841
40.00	0.9782	0.9769	0.9737
50.00	0.9709	0.9689	0.9646
60.00	0.9664	0.9634	0.9584
70.00	0.9666	0.9624	0.9571
80.00	0.9731	0.9672	0.9625
90.00	0.9866	0.9786	0.9753
100.00	1.0081	0.9975	0.9967
120.00	1.0776	1.0595	1.0681
140.00	1.1593	1.1340	1.1554
160.00	1.1491	1.1314	1.1478

Sensitivities

	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
Output Sensitivity (V/g)	2.500	2.500	2.500
Cross-axis Coupling (g/g)	0.12%	0.12%	0.04%