The calibration sheet attached is the original calibration sheet for your REF TEK product and includes contact information and branding for the company that performed the testing.

Reftek Systems Inc. purchased the REF TEK product line in May 2020.

Reftek Systems will honour existing product warranties and extended warranties.

ANY QUESTIONS OR REQUESTS FOR SUPPORT SHOULD BE ADDRESSED AS FOLLOWS:

Sales & Administrative: sales@reftek.com

Support & Engineering: support@reftek.com

Accounting: accounting@reftek.com

Address: 36 Topple Drive, Dartmouth, NS Canada B3B 1L6

Phone: +1-902-444-7650

Fax: +1-902-444-7651

Trimble Navigation Limited
1600 Tenth Street
Suite A
Plano, Texas 75074
Support phone: 1-888-879-2207
Support Email: reftek_support@trimble.com
www.trimble.com/infrastructure

REF TEK 147A-01/3
S/N: 14913

Normalized Magnitude-frequency Characteristics

Freq.(Hz)	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
1.00	1.0017	1.0020	1.0021
10.00	1.0000	1.0000	1.0000
20.00	0.9952	0.9943	0.9942
30.00	0.9883	0.9862	0.9860
40.00	0.9807	0.9772	0.9769
50.00	0.9741	0.9693	0.9692
60.00	0.9699	0.9638	0.9642
70.00	0.9697	0.9626	0.9640
80.00	0.9749	0.9671	0.9702
90.00	0.9860	0.9779	0.9833
100.00	1.0039	0.9958	1.0042
120.00	1.0608	1.0532	1.0707
140.00	1.1271	1.1168	1.1435
160.00	1.1261	1.1032	1.1231

Sensitivities

	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
Output Sensitivity (V/g)	2.500	2.501	2.501
Cross-axis Coupling (g/g)	0.16%	0.44%	0.56%