The calibration sheet attached is the original calibration sheet for your REF TEK product and includes contact information and branding for the company that performed the testing.

Reftek Systems Inc. purchased the REF TEK product line in May 2020.

Reftek Systems will honour existing product warranties and extended warranties.

ANY QUESTIONS OR REQUESTS FOR SUPPORT SHOULD BE ADDRESSED AS FOLLOWS:

Sales & Administrative: sales@reftek.com

Support & Engineering: support@reftek.com

Accounting: accounting@reftek.com

Address: 36 Topple Drive, Dartmouth, NS Canada B3B 1L6

Phone: +1-902-444-7650

Fax: +1-902-444-7651

Trimble Navigation Limited
1600 Tenth Street
Suite A
Plano, Texas 75074
Support phone: 1-888-879-2207
Support Email: reftek_support@trimble.com
www.trimble.com/infrastructure

REF TEK 147A-01/3/INT/SM P/N:97996
S/N: 15115

Normalized Magnitude-frequency Characteristics

Freq.(Hz)	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
1.00	1.0022	1.0019	1.0029
10.00	1.0000	1.0000	1.0000
20.00	0.9938	0.9945	0.9918
30.00	0.9850	0.9866	0.9801
40.00	0.9755	0.9776	0.9674
50.00	0.9676	0.9694	0.9563
60.00	0.9630	0.9633	0.9486
70.00	0.9639	0.9609	0.9464
80.00	0.9720	0.9634	0.9512
90.00	0.9881	0.9717	0.9633
100.00	1.0132	0.9862	0.9833
120.00	1.0918	1.0349	1.0445
140.00	1.1728	1.0939	1.1053
160.00	1.1320	1.0989	1.0887

Sensitivities

	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
Output Sensitivity (V/g)	2.502	2.500	2.499
Cross-axis Coupling (g/g)	0.40%	0.64%	0.76%