The calibration sheet attached is the original calibration sheet for your REF TEK product and includes contact information and branding for the company that performed the testing.

Reftek Systems Inc. purchased the REF TEK product line in May 2020.

Reftek Systems will honour existing product warranties and extended warranties.

ANY QUESTIONS OR REQUESTS FOR SUPPORT SHOULD BE ADDRESSED AS FOLLOWS:

Sales & Administrative: sales@reftek.com

Support & Engineering: support@reftek.com

Accounting: accounting@reftek.com

Address: 36 Topple Drive, Dartmouth, NS Canada B3B 1L6

Phone: +1-902-444-7650

Fax: +1-902-444-7651

Trimble Navigation Limited
1600 Tenth Street
Suite A
Plano, Texas 75074
Support phone: 1-888-879-2207
Support Email: reftek_support@trimble.com
www.trimble.com/infrastructure

REF TEK 147A-01/3/INT/SM P/N:97996
S/N: 15117

Normalized Magnitude-frequency Characteristics

Freq.(Hz)	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
1.00	1.0024	1.0020	1.0025
10.00	1.0000	1.0000	1.0000
20.00	0.9933	0.9943	0.9929
30.00	0.9838	0.9862	0.9826
40.00	0.9735	0.9772	0.9712
50.00	0.9650	0.9693	0.9611
60.00	0.9599	0.9638	0.9539
70.00	0.9605	0.9628	0.9516
80.00	0.9687	0.9677	0.9559
90.00	0.9852	0.9794	0.9676
100.00	1.0113	0.9987	0.9874
120.00	1.0937	1.0627	1.0529
140.00	1.1777	1.1388	1.1265
160.00	1.1251	1.1272	1.1066

Sensitivities

	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
Output Sensitivity (V/g)	2.501	2.501	2.499
Cross-axis Coupling (g/g)	0.00%	0.60%	0.44%