The calibration sheet attached is the original calibration sheet for your REF TEK product and includes contact information and branding for the company that performed the testing.

Reftek Systems Inc. purchased the REF TEK product line in May 2020.

Reftek Systems will honour existing product warranties and extended warranties.

ANY QUESTIONS OR REQUESTS FOR SUPPORT SHOULD BE ADDRESSED AS FOLLOWS:

Sales & Administrative: sales@reftek.com

Support & Engineering: support@reftek.com

Accounting: accounting@reftek.com

Address: 36 Topple Drive, Dartmouth, NS Canada B3B 1L6

Phone: +1-902-444-7650

Fax: +1-902-444-7651

Trimble Navigation Limited
1600 Tenth Street
Suite A
Plano, Texas 75074
Support phone: 1-888-879-2207
Support Email: reftek_support@trimble.com
www.trimble.com/infrastructure

REF TEK 147A-01/3/INT/SM P/N:97996
S/N: 15126

Normalized Magnitude-frequency Characteristics

Freq.(Hz)	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
1.00	1.0028	1.0028	1.0028
10.00	1.0000	1.0000	1.0000
20.00	0.9922	0.9922	0.9923
30.00	0.9812	0.9809	0.9814
40.00	0.9691	0.9683	0.9694
50.00	0.9588	0.9570	0.9591
60.00	0.9519	0.9486	0.9523
70.00	0.9509	0.9455	0.9511
80.00	0.9576	0.9491	0.9574
90.00	0.9727	0.9605	0.9719
100.00	0.9973	0.9805	0.9956
120.00	1.0759	1.0488	1.0718
140.00	1.1567	1.1299	1.1544
160.00	1.1127	1.1152	1.1271

Sensitivities

	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
Output Sensitivity (V/g)	2.501	2.501	2.502
Cross-axis Coupling (g/g)	0.16%	0.76%	0.28%