The calibration sheet attached is the original calibration sheet for your REF TEK product and includes contact information and branding for the company that performed the testing.

Reftek Systems Inc. purchased the REF TEK product line in May 2020.

Reftek Systems will honour existing product warranties and extended warranties.

ANY QUESTIONS OR REQUESTS FOR SUPPORT SHOULD BE ADDRESSED AS FOLLOWS:

Sales & Administrative: sales@reftek.com

Support & Engineering: support@reftek.com

Accounting: accounting@reftek.com

Address: 36 Topple Drive, Dartmouth, NS Canada B3B 1L6

Phone: +1-902-444-7650

Fax: +1-902-444-7651

Trimble Navigation Limited
1600 Tenth Street
Suite A
Plano, Texas 75074
Support phone: 1-888-879-2207
Support Email: reftek_support@trimble.com
www.trimble.com/infrastructure

REF TEK 147A-01/3/INT/SM P/N:97996
S/N: 15130

Normalized Magnitude-frequency Characteristics

Freq.(Hz)	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
1.00	1.0025	1.0025	1.0029
10.00	1.0000	1.0000	1.0000
20.00	0.9929	0.9930	0.9918
30.00	0.9828	0.9829	0.9803
40.00	0.9717	0.9717	0.9676
50.00	0.9620	0.9618	0.9568
60.00	0.9554	0.9547	0.9495
70.00	0.9540	0.9525	0.9482
80.00	0.9596	0.9568	0.9547
90.00	0.9728	0.9682	0.9695
100.00	0.9946	0.9878	0.9938
120.00	1.0648	1.0524	1.0702
140.00	1.1381	1.1275	1.1465
160.00	1.1002	1.1174	1.1041

Sensitivities

	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
Output Sensitivity (V/g)	2.500	2.501	2.499
Cross-axis Coupling (g/g)	0.08%	0.56%	0.80%