



REF TEK

SYSTEMS INC.

The calibration sheet attached is the original calibration sheet for your REF TEK product and includes contact information and branding for the company that performed the testing.

Reftek Systems Inc. purchased the REF TEK product line in May 2020.

Reftek Systems will honour existing product warranties and extended warranties.

ANY QUESTIONS OR REQUESTS FOR SUPPORT SHOULD BE ADDRESSED AS FOLLOWS:

Sales & Administrative: sales@reftek.com

Support & Engineering: support@reftek.com

Accounting: accounting@reftek.com

Address: 36 Topple Drive, Dartmouth, NS Canada B3B 1L6

Phone: +1-902-444-7650

Fax: +1-902-444-7651

Trimble Navigation Limited
 1600 Tenth Street
 Suite A
 Plano, Texas 75074
 Support phone: 1-888-879-2207
 Support Email: reftek_support@trimble.com
www.trimble.com/infrastructure



REF TEK 147A-01/3/INT/SM P/N:97996
S/N: 15131

Normalized Magnitude-frequency Characteristics

Freq.(Hz)	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
1.00	1.0018	1.0015	1.0021
10.00	1.0000	1.0000	1.0000
20.00	0.9948	0.9957	0.9942
30.00	0.9874	0.9893	0.9859
40.00	0.9789	0.9821	0.9766
50.00	0.9714	0.9755	0.9683
60.00	0.9660	0.9705	0.9626
70.00	0.9647	0.9687	0.9614
80.00	0.9689	0.9714	0.9663
90.00	0.9795	0.9791	0.9783
100.00	0.9976	0.9926	0.9984
120.00	1.0595	1.0390	1.0665
140.00	1.1389	1.0979	1.1514
160.00	1.1398	1.1050	1.1463

Sensitivities

	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
Output Sensitivity (V/g)	2.499	2.500	2.502
Cross-axis Coupling (g/g)	0.20%	0.68%	0.12%