



REF TEK

SYSTEMS INC.

The calibration sheet attached is the original calibration sheet for your REF TEK product and includes contact information and branding for the company that performed the testing.

Reftek Systems Inc. purchased the REF TEK product line in May 2020.

Reftek Systems will honour existing product warranties and extended warranties.

ANY QUESTIONS OR REQUESTS FOR SUPPORT SHOULD BE ADDRESSED AS FOLLOWS:

Sales & Administrative: sales@reftek.com

Support & Engineering: support@reftek.com

Accounting: accounting@reftek.com

Address: 36 Topple Drive, Dartmouth, NS Canada B3B 1L6

Phone: +1-902-444-7650

Fax: +1-902-444-7651

Trimble Navigation Limited
 1600 Tenth Street
 Suite A
 Plano, Texas 75074
 Support phone: 1-888-879-2207
 Support Email: reftek_support@trimble.com
www.trimble.com/infrastructure



REF TEK 147A-01/3/INT/SM P/N:97996
S/N: 15138

Normalized Magnitude-frequency Characteristics

Freq.(Hz)	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
1.00	1.0028	1.0026	1.0027
10.00	1.0000	1.0000	1.0000
20.00	0.9922	0.9926	0.9924
30.00	0.9811	0.9821	0.9815
40.00	0.9691	0.9704	0.9696
50.00	0.9588	0.9601	0.9592
60.00	0.9522	0.9529	0.9521
70.00	0.9514	0.9510	0.9506
80.00	0.9584	0.9559	0.9564
90.00	0.9738	0.9684	0.9704
100.00	0.9986	0.9893	0.9936
120.00	1.0765	1.0577	1.0697
140.00	1.1533	1.1339	1.1559
160.00	1.1058	1.1140	1.1326

Sensitivities

	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
Output Sensitivity (V/g)	2.501	2.502	2.501
Cross-axis Coupling (g/g)	0.24%	0.20%	0.20%