The calibration sheet attached is the original calibration sheet for your REF TEK product and includes contact information and branding for the company that performed the testing.

Reftek Systems Inc. purchased the REF TEK product line in May 2020.

Reftek Systems will honour existing product warranties and extended warranties.

ANY QUESTIONS OR REQUESTS FOR SUPPORT SHOULD BE ADDRESSED AS FOLLOWS:

Sales & Administrative: sales@reftek.com

Support & Engineering: support@reftek.com

Accounting: accounting@reftek.com

Address: 36 Topple Drive, Dartmouth, NS Canada B3B 1L6

Phone: +1-902-444-7650

Fax: +1-902-444-7651

Trimble Navigation Limited
1600 Tenth Street
Suite A
Plano, Texas 75074
Support phone: 1-888-879-2207
Support Email: reftek_support@trimble.com
www.trimble.com/infrastructure

REF TEK 147A-01/3/INT/SM P/N:97996 S/N: 15139

Normalized Magnitude-frequency Characteristics

Freq.(Hz)	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
1.00	1.0022	1.0021	1.0024
10.00	1.0000	1.0000	1.0000
20.00	0.9937	0.9941	0.9934
30.00	0.9845	0.9856	0.9839
40.00	0.9742	0.9763	0.9732
50.00	0.9649	0.9682	0.9637
60.00	0.9581	0.9629	0.9568
70.00	0.9557	0.9622	0.9544
80.00	0.9592	0.9677	0.9581
90.00	0.9695	0.9800	0.9685
100.00	0.9877	1.0001	0.9863
120.00	1.0503	1.0646	1.0452
140.00	1.1322	1.1384	1.1147
160.00	1.1420	1.1289	1.1149

Sensitivities

	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
Output Sensitivity (V/g)	2.503	2.500	2.500
Cross-axis Coupling (g/g)	0.40%	0.88%	0.56%