



REF TEK

SYSTEMS INC.

The calibration sheet attached is the original calibration sheet for your REF TEK product and includes contact information and branding for the company that performed the testing.

Reftek Systems Inc. purchased the REF TEK product line in May 2020.

Reftek Systems will honour existing product warranties and extended warranties.

ANY QUESTIONS OR REQUESTS FOR SUPPORT SHOULD BE ADDRESSED AS FOLLOWS:

Sales & Administrative: sales@reftek.com

Support & Engineering: support@reftek.com

Accounting: accounting@reftek.com

Address: 36 Topple Drive, Dartmouth, NS Canada B3B 1L6

Phone: +1-902-444-7650

Fax: +1-902-444-7651

Trimble Navigation Limited
1600 Tenth Street
Suite A
Plano, Texas 75074
Support phone: 1-888-879-2207
Support Email: reftek_support@trimble.com
www.trimble.com/infrastructure



REF TEK 147A-01/3/INT/SM P/N:97996
S/N: 15148

Normalized Magnitude-frequency Characteristics

Freq.(Hz)	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
1.00	1.0024	1.0025	1.0029
10.00	1.0000	1.0000	1.0000
20.00	0.9933	0.9929	0.9918
30.00	0.9837	0.9828	0.9801
40.00	0.9728	0.9715	0.9672
50.00	0.9631	0.9613	0.9557
60.00	0.9558	0.9538	0.9475
70.00	0.9532	0.9511	0.9448
80.00	0.9565	0.9548	0.9493
90.00	0.9666	0.9656	0.9617
100.00	0.9844	0.9845	0.9830
120.00	1.0446	1.0483	1.0533
140.00	1.1175	1.1255	1.1321
160.00	1.1134	1.1198	1.1119

Sensitivities

	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
Output Sensitivity (V/g)	2.502	2.499	2.503
Cross-axis Coupling (g/g)	0.08%	0.16%	0.52%