



REF TEK

SYSTEMS INC.

The calibration sheet attached is the original calibration sheet for your REF TEK product and includes contact information and branding for the company that performed the testing.

Reftek Systems Inc. purchased the REF TEK product line in May 2020.

Reftek Systems will honour existing product warranties and extended warranties.

ANY QUESTIONS OR REQUESTS FOR SUPPORT SHOULD BE ADDRESSED AS FOLLOWS:

Sales & Administrative: sales@reftek.com

Support & Engineering: support@reftek.com

Accounting: accounting@reftek.com

Address: 36 Topple Drive, Dartmouth, NS Canada B3B 1L6

Phone: +1-902-444-7650

Fax: +1-902-444-7651

Trimble Navigation Limited
1600 Tenth Street
Suite A
Plano, Texas 75074
Support phone: 1-888-879-2207
Support Email: reftek_support@trimble.com
www.trimble.com/infrastructure



REF TEK 147A-01/3/INT/SM P/N:97996
S/N: 15149

Normalized Magnitude-frequency Characteristics

Freq.(Hz)	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
1.00	1.0028	1.0025	1.0023
10.00	1.0000	1.0000	1.0000
20.00	0.9923	0.9929	0.9936
30.00	0.9814	0.9828	0.9846
40.00	0.9695	0.9716	0.9749
50.00	0.9592	0.9615	0.9668
60.00	0.9523	0.9542	0.9619
70.00	0.9511	0.9519	0.9625
80.00	0.9572	0.9561	0.9703
90.00	0.9713	0.9676	0.9858
100.00	0.9940	0.9875	1.0102
120.00	1.0643	1.0546	1.0859
140.00	1.1295	1.1368	1.1625
160.00	1.0806	1.1331	1.1214

Sensitivities

	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
Output Sensitivity (V/g)	2.501	2.502	2.499
Cross-axis Coupling (g/g)	0.08%	0.60%	0.60%