



REF TEK

SYSTEMS INC.

The calibration sheet attached is the original calibration sheet for your REF TEK product and includes contact information and branding for the company that performed the testing.

Reftek Systems Inc. purchased the REF TEK product line in May 2020.

Reftek Systems will honour existing product warranties and extended warranties.

ANY QUESTIONS OR REQUESTS FOR SUPPORT SHOULD BE ADDRESSED AS FOLLOWS:

Sales & Administrative: sales@reftek.com

Support & Engineering: support@reftek.com

Accounting: accounting@reftek.com

Address: 36 Topple Drive, Dartmouth, NS Canada B3B 1L6

Phone: +1-902-444-7650

Fax: +1-902-444-7651

Trimble Navigation Limited
1600 Tenth Street
Suite A
Plano, Texas 75074
Support phone: 1-888-879-2207
Support Email: reftek_support@trimble.com
www.trimble.com/infrastructure



REF TEK 147A-01/3/INT

P/N:97837

S/N: 14002

Normalized Magnitude-frequency Characteristics

Freq.(Hz)	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
1.00	1.0016	1.0041	1.0024
10.00	1.0000	1.0000	1.0000
20.00	0.9954	0.9895	0.9932
30.00	0.9889	0.9766	0.9834
40.00	0.9818	0.9650	0.9727
50.00	0.9759	0.9572	0.9634
60.00	0.9725	0.9541	0.9571
70.00	0.9733	0.9565	0.9560
80.00	0.9800	0.9652	0.9617
90.00	0.9930	0.9794	0.9750
100.00	1.0133	0.9995	0.9968
120.00	1.0762	1.0559	1.0662
140.00	1.1394	1.1082	1.1368
160.00	1.1025	1.0784	1.0981

Sensitivities

	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
OutputSensitivity (V/g)	2.512	2.504	2.505
Cross-axis Coupling (g/g)	0.12%	0.08%	0.24%