



REF TEK

SYSTEMS INC.

The calibration sheet attached is the original calibration sheet for your REF TEK product and includes contact information and branding for the company that performed the testing.

Reftek Systems Inc. purchased the REF TEK product line in May 2020.

Reftek Systems will honour existing product warranties and extended warranties.

ANY QUESTIONS OR REQUESTS FOR SUPPORT SHOULD BE ADDRESSED AS FOLLOWS:

Sales & Administrative: sales@reftek.com

Support & Engineering: support@reftek.com

Accounting: accounting@reftek.com

Address: 36 Topple Drive, Dartmouth, NS Canada B3B 1L6

Phone: +1-902-444-7650

Fax: +1-902-444-7651

Trimble Navigation Limited
1600 Tenth Street
Suite A
Plano, Texas 75074
Support phone: 1-888-879-2207
Support Email: reftek_support@trimble.com
www.trimble.com/infrastructure



REF TEK 147A-01/3/INT P/N:97837
S/N: 14008

Normalized Magnitude-frequency Characteristics

Freq.(Hz)	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
1.00	1.0019	1.0032	1.0020
10.00	1.0000	1.0000	1.0000
20.00	0.9948	0.9911	0.9943
30.00	0.9873	0.9786	0.9861
40.00	0.9791	0.9652	0.9771
50.00	0.9721	0.9540	0.9691
60.00	0.9676	0.9469	0.9638
70.00	0.9673	0.9465	0.9628
80.00	0.9726	0.9545	0.9677
90.00	0.9838	0.9712	0.9790
100.00	1.0013	0.9974	0.9976
120.00	1.0532	1.0737	1.0570
140.00	1.0948	1.1305	1.1210
160.00	1.0456	1.0608	1.1009

Sensitivities

	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
Output Sensitivity (V/g)	2.504	2.500	2.496
Cross-axis Coupling (g/g)	0.12%	0.04%	0.24%