



REF TEK

SYSTEMS INC.

The calibration sheet attached is the original calibration sheet for your REF TEK product and includes contact information and branding for the company that performed the testing.

Reftek Systems Inc. purchased the REF TEK product line in May 2020.

Reftek Systems will honour existing product warranties and extended warranties.

ANY QUESTIONS OR REQUESTS FOR SUPPORT SHOULD BE ADDRESSED AS FOLLOWS:

Sales & Administrative: sales@reftek.com

Support & Engineering: support@reftek.com

Accounting: accounting@reftek.com

Address: 36 Topple Drive, Dartmouth, NS Canada B3B 1L6

Phone: +1-902-444-7650

Fax: +1-902-444-7651

Trimble Navigation Limited
1600 Tenth Street
Suite A
Plano, Texas 75074
Support phone: 1-888-879-2207
Support Email: reftek_support@trimble.com
www.trimble.com/infrastructure



REF TEK 147A-01/3/INT P/N:97837
S/N: 14009

Normalized Magnitude-frequency Characteristics

Freq.(Hz)	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
1.00	1.0031	1.0031	1.0033
10.00	1.0000	1.0000	1.0000
20.00	0.9917	0.9916	0.9911
30.00	0.9806	0.9804	0.9791
40.00	0.9699	0.9688	0.9667
50.00	0.9622	0.9599	0.9567
60.00	0.9592	0.9550	0.9506
70.00	0.9622	0.9558	0.9499
80.00	0.9727	0.9633	0.9557
90.00	0.9899	0.9772	0.9682
100.00	1.0142	0.9978	0.9879
120.00	1.0820	1.0568	1.0505
140.00	1.1433	1.1116	1.1265
160.00	1.1085	1.0832	1.1306

Sensitivities

	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
Output Sensitivity (V/g)	2.506	2.503	2.494
Cross-axis Coupling (g/g)	0.08%	0.08%	0.28%