



REF TEK

SYSTEMS INC.

The calibration sheet attached is the original calibration sheet for your REF TEK product and includes contact information and branding for the company that performed the testing.

Reftek Systems Inc. purchased the REF TEK product line in May 2020.

Reftek Systems will honour existing product warranties and extended warranties.

ANY QUESTIONS OR REQUESTS FOR SUPPORT SHOULD BE ADDRESSED AS FOLLOWS:

Sales & Administrative: sales@reftek.com

Support & Engineering: support@reftek.com

Accounting: accounting@reftek.com

Address: 36 Topple Drive, Dartmouth, NS Canada B3B 1L6

Phone: +1-902-444-7650

Fax: +1-902-444-7651

Trimble Navigation Limited
1600 Tenth Street
Suite A
Plano, Texas 75074
Support phone: 1-888-879-2207
Support Email: reftek_support@trimble.com
www.trimble.com/infrastructure



147A-01/3/INT

P/N:97837

S/N: 14019

Normalized Magnitude-frequency Characteristics

Freq.(Hz)	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
1.00	1.0021	1.0016	1.0024
10.00	1.0000	1.0000	1.0000
20.00	0.9942	0.9956	0.9933
30.00	0.9860	0.9892	0.9837
40.00	0.9770	0.9822	0.9731
50.00	0.9695	0.9763	0.9637
60.00	0.9649	0.9726	0.9570
70.00	0.9651	0.9726	0.9552
80.00	0.9719	0.9779	0.9596
90.00	0.9855	0.9888	0.9709
100.00	1.0071	1.0061	0.9897
120.00	1.0742	1.0604	1.0493
140.00	1.1468	1.1225	1.1098
160.00	1.1303	1.1202	1.0802

Sensitivities

	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
Output Sensitivity (V/g)	2.499	2.500	2.502
Cross-axis Coupling (g/g)	0.64%	0.04%	0.16%