



REF TEK

SYSTEMS INC.

The calibration sheet attached is the original calibration sheet for your REF TEK product and includes contact information and branding for the company that performed the testing.

Reftek Systems Inc. purchased the REF TEK product line in May 2020.

Reftek Systems will honour existing product warranties and extended warranties.

ANY QUESTIONS OR REQUESTS FOR SUPPORT SHOULD BE ADDRESSED AS FOLLOWS:

Sales & Administrative: sales@reftek.com

Support & Engineering: support@reftek.com

Accounting: accounting@reftek.com

Address: 36 Topple Drive, Dartmouth, NS Canada B3B 1L6

Phone: +1-902-444-7650

Fax: +1-902-444-7651

Trimble Navigation Limited
 1600 Tenth Street
 Suite A
 Plano, Texas 75074
 Support phone: 1-888-879-2207
 Support Email: reftek_support@trimble.com
www.trimble.com/infrastructure



REF TEK 147A-01/3/INT

P/N:97837

S/N: 14023

Normalized Magnitude-frequency Characteristics

Freq.(Hz)	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
1.00	1.0018	1.0018	1.0017
10.00	1.0000	1.0000	1.0000
20.00	0.9949	0.9948	0.9953
30.00	0.9875	0.9874	0.9884
40.00	0.9792	0.9792	0.9806
50.00	0.9719	0.9721	0.9735
60.00	0.9668	0.9673	0.9681
70.00	0.9656	0.9667	0.9661
80.00	0.9695	0.9716	0.9686
90.00	0.9792	0.9824	0.9763
100.00	0.9952	0.9999	0.9900
120.00	1.0458	1.0538	1.0364
140.00	1.0977	1.1070	1.0948
160.00	1.0742	1.0777	1.1020

Sensitivities

	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
Output Sensitivity (V/g)	2.500	2.497	2.497
Cross-axis Coupling (g/g)	0.88%	0.40%	0.24%