



REF TEK

SYSTEMS INC.

The calibration sheet attached is the original calibration sheet for your REF TEK product and includes contact information and branding for the company that performed the testing.

Reftek Systems Inc. purchased the REF TEK product line in May 2020.

Reftek Systems will honour existing product warranties and extended warranties.

ANY QUESTIONS OR REQUESTS FOR SUPPORT SHOULD BE ADDRESSED AS FOLLOWS:

Sales & Administrative: sales@reftek.com

Support & Engineering: support@reftek.com

Accounting: accounting@reftek.com

Address: 36 Topple Drive, Dartmouth, NS Canada B3B 1L6

Phone: +1-902-444-7650

Fax: +1-902-444-7651

Trimble Navigation Limited
1600 Tenth Street
Suite A
Plano, Texas 75074
Support phone: 1-888-879-2207
Support Email: reftek_support@trimble.com
www.trimble.com/infrastructure



REF TEK 147A-01/3/INT P/N:97837
S/N: 14024

Normalized Magnitude-frequency Characteristics

Freq.(Hz)	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
1.00	1.0014	1.0018	1.0019
10.00	1.0000	1.0000	1.0000
20.00	0.9959	0.9949	0.9946
30.00	0.9901	0.9876	0.9870
40.00	0.9836	0.9794	0.9785
50.00	0.9778	0.9721	0.9713
60.00	0.9739	0.9668	0.9666
70.00	0.9733	0.9653	0.9663
80.00	0.9773	0.9688	0.9719
90.00	0.9862	0.9779	0.9841
100.00	1.0008	0.9933	1.0036
120.00	1.0475	1.0441	1.0661
140.00	1.1010	1.1051	1.1364
160.00	1.0964	1.1079	1.1221

Sensitivities

	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
Output Sensitivity (V/g)	2.499	2.501	2.503
Cross-axis Coupling (g/g)	0.20%	0.16%	0.56%