



REF TEK

SYSTEMS INC.

The calibration sheet attached is the original calibration sheet for your REF TEK product and includes contact information and branding for the company that performed the testing.

Reftek Systems Inc. purchased the REF TEK product line in May 2020.

Reftek Systems will honour existing product warranties and extended warranties.

ANY QUESTIONS OR REQUESTS FOR SUPPORT SHOULD BE ADDRESSED AS FOLLOWS:

Sales & Administrative: sales@reftek.com

Support & Engineering: support@reftek.com

Accounting: accounting@reftek.com

Address: 36 Topple Drive, Dartmouth, NS Canada B3B 1L6

Phone: +1-902-444-7650

Fax: +1-902-444-7651

Trimble Navigation Limited
1600 Tenth Street
Suite A
Plano, Texas 75074
Support phone: 1-888-879-2207
Support Email: reftek_support@trimble.com
www.trimble.com/infrastructure



REF TEK 147A-01/3/INT P/N:97837

S/N: 14026

Normalized Magnitude-frequency Characteristics

Freq.(Hz)	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
1.00	1.0042	1.0036	1.0032
10.00	1.0000	1.0000	1.0000
20.00	0.9892	0.9905	0.9913
30.00	0.9760	0.9780	0.9796
40.00	0.9640	0.9656	0.9674
50.00	0.9560	0.9562	0.9577
60.00	0.9528	0.9511	0.9519
70.00	0.9549	0.9514	0.9513
80.00	0.9626	0.9581	0.9567
90.00	0.9749	0.9711	0.9678
100.00	0.9918	0.9909	0.9847
120.00	1.0376	1.0526	1.0339
140.00	1.0824	1.1293	1.0850
160.00	1.0705	1.1417	1.0770

Sensitivities

	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
Output Sensitivity (V/g)	2.500	2.498	2.499
Cross-axis Coupling (g/g)	0.04%	0.12%	0.04%