The calibration sheet attached is the original calibration sheet for your REF TEK product and includes contact information and branding for the company that performed the testing.

Reftek Systems Inc. purchased the REF TEK product line in May 2020.

Reftek Systems will honour existing product warranties and extended warranties.

ANY QUESTIONS OR REQUESTS FOR SUPPORT SHOULD BE ADDRESSED AS FOLLOWS:

Sales & Administrative: sales@reftek.com

Support & Engineering: support@reftek.com

Accounting: accounting@reftek.com

Address: 36 Topple Drive, Dartmouth, NS Canada B3B 1L6

Phone: +1-902-444-7650

Fax: +1-902-444-7651

Trimble Navigation Limited
1600 Tenth Street
Suite A
Plano, Texas 75074
Support phone: 1-888-879-2207
Support Email: reftek_support@trimble.com
www.trimble.com/infrastructure

REF TEK 147A-01/3/INT P/N:97837
S/N: 14038

Normalized Magnitude-frequency Characteristics

Freq.(Hz)	Z-Axis (Vertical)	X-Axis (East/West)	Y-Axis (North/South)
1.00	1.0018	1.0027	1.0016
10.00	1.0000	1.0000	1.0000
20.00	0.9948	0.9924	0.9955
30.00	0.9875	0.9815	0.9891
40.00	0.9795	0.9693	0.9819
50.00	0.9727	0.9585	0.9755
60.00	0.9686	0.9507	0.9711
70.00	0.9690	0.9480	0.9704
80.00	0.9754	0.9520	0.9746
90.00	0.9885	0.9635	0.9845
100.00	1.0091	0.9832	1.0008
120.00	1.0736	1.0474	1.0548
140.00	1.1411	1.1167	1.1206
160.00	1.1129	1.0944	1.1213

Sensitivities

	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
OutputSensitivity (V/g)	2.501	2.500	2.497
Cross-axis Coupling (g/g)	0.40%	0.16%	0.08%