The calibration sheet attached is the original calibration sheet for your REF TEK product and includes contact information and branding for the company that performed the testing.

Reftek Systems Inc. purchased the REF TEK product line in May 2020.

Reftek Systems will honour existing product warranties and extended warranties.

ANY QUESTIONS OR REQUESTS FOR SUPPORT SHOULD BE ADDRESSED AS FOLLOWS:

Sales & Administrative: sales@reftek.com

Support & Engineering: support@reftek.com

Accounting: accounting@reftek.com

Address: 36 Topple Drive, Dartmouth, NS Canada B3B 1L6

Phone: +1-902-444-7650

Fax: +1-902-444-7651

Trimble Navigation Limited
1600 Tenth Street
Suite A
Plano, Texas 75074
Support phone: 1-888-879-2207
Support Email: reftek_support@trimble.com
www.trimble.com/infrastructure

REF TEK 147A-01/3/INT P/N:97837
S/N: 14040

Normalized Magnitude-frequency Characteristics

Freq.(Hz)	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
1.00	1.0022	1.0014	1.0019
10.00	1.0000	1.0000	1.0000
20.00	0.9938	0.9959	0.9946
30.00	0.9848	0.9900	0.9868
40.00	0.9745	0.9833	0.9780
50.00	0.9652	0.9773	0.9703
60.00	0.9582	0.9731	0.9649
70.00	0.9555	0.9723	0.9637
80.00	0.9584	0.9762	0.9682
90.00	0.9678	0.9855	0.9790
100.00	0.9845	1.0013	0.9972
120.00	1.0418	1.0551	1.0570
140.00	1.1135	1.1261	1.1275
160.00	1.1178	1.1364	1.1197

Sensitivities

	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
OutputSensitivity (V/g)	2.501	2.502	2.503
Cross-axis Coupling (g/g)	0.28%	0.40%	0.16%