The calibration sheet attached is the original calibration sheet for your REF TEK product and includes contact information and branding for the company that performed the testing.

Reftek Systems Inc. purchased the REF TEK product line in May 2020.

Reftek Systems will honour existing product warranties and extended warranties.

ANY QUESTIONS OR REQUESTS FOR SUPPORT SHOULD BE ADDRESSED AS FOLLOWS:

Sales & Administrative: sales@reftek.com

Support & Engineering: support@reftek.com

Accounting: accounting@reftek.com

Address: 36 Topple Drive, Dartmouth, NS Canada B3B 1L6

Phone: +1-902-444-7650

Fax: +1-902-444-7651

Trimble Navigation Limited
1600 Tenth Street
Suite A
Plano, Texas 75074
Support phone: 1-888-879-2207
Support Email: reftek_support@trimble.com
www.trimble.com/infrastructure

REF TEK 147A-01/3/INT P/N:97837
S/N: 14049

Normalized Magnitude-frequency Characteristics

Freq.(Hz)	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
1.00	1.0020	1.0017	1.0018
10.00	1.0000	1.0000	1.0000
20.00	0.9944	0.9952	0.9949
30.00	0.9863	0.9882	0.9876
40.00	0.9772	0.9801	0.9792
50.00	0.9689	0.9727	0.9715
60.00	0.9627	0.9670	0.9658
70.00	0.9607	0.9646	0.9636
80.00	0.9641	0.9668	0.9664
90.00	0.9739	0.9742	0.9748
100.00	0.9910	0.9878	0.9897
120.00	1.0496	1.0352	1.0408
140.00	1.1234	1.0977	1.1064
160.00	1.1243	1.1120	1.1168

Sensitivities

	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
OutputSensitivity (V/g)	2.503	2.499	2.500
Cross-axis Coupling (g/g)	0.20%	0.28%	0.16%