



REF TEK

SYSTEMS INC.

The calibration sheet attached is the original calibration sheet for your REF TEK product and includes contact information and branding for the company that performed the testing.

Reftek Systems Inc. purchased the REF TEK product line in May 2020.

Reftek Systems will honour existing product warranties and extended warranties.

ANY QUESTIONS OR REQUESTS FOR SUPPORT SHOULD BE ADDRESSED AS FOLLOWS:

Sales & Administrative: sales@reftek.com

Support & Engineering: support@reftek.com

Accounting: accounting@reftek.com

Address: 36 Topple Drive, Dartmouth, NS Canada B3B 1L6

Phone: +1-902-444-7650

Fax: +1-902-444-7651

Trimble Navigation Limited
1600 Tenth Street
Suite A
Plano, Texas 75074
Support phone: 1-888-879-2207
Support Email: reftek_support@trimble.com
www.trimble.com/infrastructure



REF TEK 147A-01/3/INT

P/N:97837

S/N: 14053

Normalized Magnitude-frequency Characteristics

Freq.(Hz)	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
1.00	1.0019	1.0022	1.0015
10.00	1.0000	1.0000	1.0000
20.00	0.9946	0.9939	0.9959
30.00	0.9868	0.9851	0.9899
40.00	0.9782	0.9752	0.9832
50.00	0.9705	0.9662	0.9771
60.00	0.9652	0.9595	0.9727
70.00	0.9642	0.9571	0.9715
80.00	0.9689	0.9603	0.9747
90.00	0.9800	0.9698	0.9830
100.00	0.9988	0.9866	0.9971
120.00	1.0612	1.0438	1.0449
140.00	1.1380	1.1144	1.1082
160.00	1.1340	1.1143	1.1259

Sensitivities

	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
Output Sensitivity (V/g)	2.498	2.498	2.500
Cross-axis Coupling (g/g)	0.16%	0.48%	0.00%