



REF TEK

SYSTEMS INC.

The calibration sheet attached is the original calibration sheet for your REF TEK product and includes contact information and branding for the company that performed the testing.

Reftek Systems Inc. purchased the REF TEK product line in May 2020.

Reftek Systems will honour existing product warranties and extended warranties.

ANY QUESTIONS OR REQUESTS FOR SUPPORT SHOULD BE ADDRESSED AS FOLLOWS:

Sales & Administrative: sales@reftek.com

Support & Engineering: support@reftek.com

Accounting: accounting@reftek.com

Address: 36 Topple Drive, Dartmouth, NS Canada B3B 1L6

Phone: +1-902-444-7650

Fax: +1-902-444-7651

Trimble Navigation Limited
1600 Tenth Street
Suite A
Plano, Texas 75074
Support phone: 1-888-879-2207
Support Email: reftek_support@trimble.com
www.trimble.com/infrastructure



REF TEK 147A-01/3/INT P/N:97837
S/N: 14055

Normalized Magnitude-frequency Characteristics

Freq.(Hz)	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
1.00	1.0022	1.0014	1.0017
10.00	1.0000	1.0000	1.0000
20.00	0.9938	0.9960	0.9951
30.00	0.9851	0.9902	0.9879
40.00	0.9755	0.9835	0.9797
50.00	0.9674	0.9773	0.9722
60.00	0.9622	0.9726	0.9666
70.00	0.9619	0.9709	0.9644
80.00	0.9680	0.9732	0.9669
90.00	0.9812	0.9802	0.9747
100.00	1.0020	0.9927	0.9887
120.00	1.0664	1.0358	1.0367
140.00	1.1312	1.0919	1.0976
160.00	1.1033	1.1014	1.1055

Sensitivities

	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
OutputSensitivity (V/g)	2.502	2.502	2.500
Cross-axis Coupling (g/g)	0.16%	0.48%	0.28%