



REF TEK

SYSTEMS INC.

The calibration sheet attached is the original calibration sheet for your REF TEK product and includes contact information and branding for the company that performed the testing.

Reftek Systems Inc. purchased the REF TEK product line in May 2020.

Reftek Systems will honour existing product warranties and extended warranties.

ANY QUESTIONS OR REQUESTS FOR SUPPORT SHOULD BE ADDRESSED AS FOLLOWS:

Sales & Administrative: sales@reftek.com

Support & Engineering: support@reftek.com

Accounting: accounting@reftek.com

Address: 36 Tople Drive, Dartmouth, NS Canada B3B 1L6

Phone: +1-902-444-7650

Fax: +1-902-444-7651

Trimble Navigation Limited
1600 Tenth Street
Suite A
Plano, Texas 75074
Support phone: 1-888-879-2207
Support Email: reftek_support@trimble.com
www.trimble.com/infrastructure



REF TEK 147A-01/3/INT

P/N:97837

S/N: 14056

Normalized Magnitude-frequency Characteristics

Freq.(Hz)	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
1.00	1.0014	1.0025	1.0018
10.00	1.0000	1.0000	1.0000
20.00	0.9961	0.9930	0.9949
30.00	0.9905	0.9828	0.9876
40.00	0.9842	0.9714	0.9795
50.00	0.9786	0.9611	0.9722
60.00	0.9749	0.9533	0.9671
70.00	0.9743	0.9502	0.9658
80.00	0.9781	0.9533	0.9697
90.00	0.9869	0.9632	0.9794
100.00	1.0013	0.9809	0.9955
120.00	1.0485	1.0409	1.0483
140.00	1.1065	1.1119	1.1092
160.00	1.1119	1.1024	1.1023

Sensitivities

	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
OutputSensitivity (V/g)	2.501	2.504	2.497
Cross-axis Coupling (g/g)	0.08%	0.08%	0.08%