



REF TEK

SYSTEMS INC.

The calibration sheet attached is the original calibration sheet for your REF TEK product and includes contact information and branding for the company that performed the testing.

Reftek Systems Inc. purchased the REF TEK product line in May 2020.

Reftek Systems will honour existing product warranties and extended warranties.

ANY QUESTIONS OR REQUESTS FOR SUPPORT SHOULD BE ADDRESSED AS FOLLOWS:

Sales & Administrative: sales@reftek.com

Support & Engineering: support@reftek.com

Accounting: accounting@reftek.com

Address: 36 Topple Drive, Dartmouth, NS Canada B3B 1L6

Phone: +1-902-444-7650

Fax: +1-902-444-7651

Trimble Navigation Limited
 1600 Tenth Street
 Suite A
 Plano, Texas 75074
 Support phone: 1-888-879-2207
 Support Email: reftek_support@trimble.com
www.trimble.com/infrastructure



REF TEK 147A-01/3/INT

P/N:97837

S/N: 15003

Normalized Magnitude-frequency Characteristics

Freq.(Hz)	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
1.00	1.0014	1.0017	1.0016
10.00	1.0000	1.0000	1.0000
20.00	0.9960	0.9952	0.9956
30.00	0.9902	0.9883	0.9894
40.00	0.9837	0.9807	0.9826
50.00	0.9780	0.9742	0.9768
60.00	0.9742	0.9699	0.9735
70.00	0.9736	0.9697	0.9741
80.00	0.9777	0.9747	0.9801
90.00	0.9868	0.9857	0.9918
100.00	1.0018	1.0033	1.0101
120.00	1.0511	1.0598	1.0660
140.00	1.1151	1.1268	1.1217
160.00	1.1347	1.1294	1.0930

Sensitivities

	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
Output Sensitivity (V/g)	2.500	2.504	2.499
Cross-axis Coupling (g/g)	0.04%	0.76%	0.04%