



REF TEK

SYSTEMS INC.

The calibration sheet attached is the original calibration sheet for your REF TEK product and includes contact information and branding for the company that performed the testing.

Reftek Systems Inc. purchased the REF TEK product line in May 2020.

Reftek Systems will honour existing product warranties and extended warranties.

ANY QUESTIONS OR REQUESTS FOR SUPPORT SHOULD BE ADDRESSED AS FOLLOWS:

Sales & Administrative: sales@reftek.com

Support & Engineering: support@reftek.com

Accounting: accounting@reftek.com

Address: 36 Tople Drive, Dartmouth, NS Canada B3B 1L6

Phone: +1-902-444-7650

Fax: +1-902-444-7651

Trimble Navigation Limited
1600 Tenth Street
Suite A
Plano, Texas 75074
Support phone: 1-888-879-2207
Support Email: reftek_support@trimble.com
www.trimble.com/infrastructure



REF TEK 147A-01/3/INT

P/N:97837

S/N: 15011

Normalized Magnitude-frequency Characteristics

Freq.(Hz)	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
1.00	1.0016	1.0016	1.0017
10.00	1.0000	1.0000	1.0000
20.00	0.9956	0.9955	0.9951
30.00	0.9893	0.9892	0.9882
40.00	0.9823	0.9823	0.9806
50.00	0.9762	0.9765	0.9741
60.00	0.9722	0.9730	0.9702
70.00	0.9717	0.9733	0.9704
80.00	0.9760	0.9789	0.9762
90.00	0.9853	0.9900	0.9878
100.00	1.0003	1.0072	1.0060
120.00	1.0468	1.0596	1.0612
140.00	1.0982	1.1138	1.1163
160.00	1.0965	1.1004	1.0938

Sensitivities

	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
Output Sensitivity (V/g)	2.502	2.501	2.500
Cross-axis Coupling (g/g)	0.20%	0.16%	0.24%