



REF TEK

SYSTEMS INC.

The calibration sheet attached is the original calibration sheet for your REF TEK product and includes contact information and branding for the company that performed the testing.

Reftek Systems Inc. purchased the REF TEK product line in May 2020.

Reftek Systems will honour existing product warranties and extended warranties.

ANY QUESTIONS OR REQUESTS FOR SUPPORT SHOULD BE ADDRESSED AS FOLLOWS:

Sales & Administrative: sales@reftek.com

Support & Engineering: support@reftek.com

Accounting: accounting@reftek.com

Address: 36 Topple Drive, Dartmouth, NS Canada B3B 1L6

Phone: +1-902-444-7650

Fax: +1-902-444-7651

Trimble Navigation Limited
 1600 Tenth Street
 Suite A
 Plano, Texas 75074
 Support phone: 1-888-879-2207
 Support Email: reftek_support@trimble.com
www.trimble.com/infrastructure



REF TEK 147A-01/3/INT

P/N:97837

S/N: 15012

Normalized Magnitude-frequency Characteristics

Freq.(Hz)	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
1.00	1.0024	1.0023	1.0022
10.00	1.0000	1.0000	1.0000
20.00	0.9932	0.9934	0.9937
30.00	0.9835	0.9840	0.9848
40.00	0.9726	0.9734	0.9748
50.00	0.9631	0.9641	0.9660
60.00	0.9563	0.9576	0.9600
70.00	0.9545	0.9558	0.9586
80.00	0.9592	0.9604	0.9635
90.00	0.9712	0.9721	0.9754
100.00	0.9915	0.9919	0.9953
120.00	1.0589	1.0571	1.0608
140.00	1.1403	1.1340	1.1398
160.00	1.1365	1.1260	1.1384

Sensitivities

	Z-Axis (Vertical)	Y-Axis (North/South)	X-Axis (East/West)
Output Sensitivity (V/g)	2.505	2.501	2.502
Cross-axis Coupling (g/g)	0.84%	0.76%	0.36%